



Barton & Loguidice, D.P.C.

Memo To: Dave Higgins
City of Mechanicville

Date: April 6, 2016

From: Don Fletcher
Vice President

Project No.: 991.017.003
Phase No.: Design

Subject: PFOA Testing of Mechanicville
Drinking Water

We have reviewed the Laboratory Report by JH Consulting Group, Inc. regarding testing for perfluorooctanic acid (PFOA) of a sample of City of Mechanicville drinking water taken on March 14, 2016. The report indicates that the testing for PFOA was completed in accordance with US EPA Method 537, which is the appropriate standard testing method, and that PFOA was not detected in the sample of Mechanicville's drinking water.

